EXHIBIT 6-A





MAINTENANCE AGREEMENT

CSA & SUPPORT SERVICES (800) 789-9774

Customer # : 440820E Agreement #: 3313AB

OCI 2 4 2009

DATE:

10/21/2009

PARTIES:

First Party:

QUINN COMPANY, a California corporation, dba QUINN POWER SYSTEMS hereinafter referred to as "QUINN"; and

Second Party:

Monterey Penninsula Water District hereinafter referred to as "OWNER".

RECITALS:

- 1. Quinn is a factory authorized Caterpillar dealer.
- 2. Owner owns certain equipment and Owner desires to retain Quinn to perform periodic preventive maintenance on such equipment, and Quinn is willing to perform such periodic preventive maintenance, on the terms and subject to the conditions set forth in this Agreement.

AGREEMENT:

The parties hereto do hereby agree as follows:

1. The Equipment. Owner now owns the following described engines and related equipment:

Caterpillar 3306ATAAC, 250kW, SN 09NR04306

All of the above-described item(s) are hereinafter collectively referred to as "the Equipment" and covered under this agreement.

2. <u>Term.</u> Starting from: 10/21/2009

This agreement is continuous until cancelled or non-renewed and shall commence on the date first written above and shall continue until the end of the coverage term as stated above or terminated by either party giving the other party thirty (30) days written notice of termination. The provisions of this Agreement relating to indemnification and limitation of Quinn's liability shall survive any termination of this Agreement.

3. <u>The Services.</u> Owner hereby engages Quinn to render certain maintenance services to the Equipment during the term of this Agreement as indicated below and described on Exhibit "A" attached hereto ("CSA PM LEVEL DESCRIPTIONS"). Additional PM coverage may be added anytime at customer's request.

<u>GUARANTEE</u>	D PERFORMANCE	FREQUENCY	ANNUAL FEE
PM Level 1 - Multi Pc			\$466,00
PM Level 2 - Annual			\$979.00

PM Load Bank 2 hours test duration

One (1) visit per year. \$1,050.00

FACTORY RECOMMENDED SERVICES

FREQUENCY

SERVICE FEE

PM 3 Cooling System Service

One (1) service every three (3) years.

\$2,237.00

The following part(s) shall be replace for the above scope of work Engine Oil, Oil Filter(s), Fuel Filter(s), Air Filter(s) Engine Coolant, Hose(s), Belt(s), Thermostat(s), Gasket(s), Sealant, Hose Clamp(s), Radiator Cap, and Misc. Parts CONT. 4.

5 .

6.

7.

10/22/2009 9:33:49 AM

Customer # : 440820F Agreement #: 3313AB

	Decidence Alexander	1	- 1 11 1	Agreement,	10101010000 11170	. 1 11	200 1000000	O :
r-ee	DUINDO THE	term (OT THIS	Adreement	OWNER	Shall	nav	()IIInn
100.	Daning the	COLLE	01 111110	rigioonioni,	OVELICI	Julian	Puly	Quilli.

Total fee excluding optional LOADBANK TEST:

\$3.682.00

| Accept [

] initial

Total fee including optional LOADBANK TEST:

\$4,732.00

I Accept [] initial

Quinn will invoice Owner in accordance with provisions of this Agreement, plus any applicable taxes, after each visit and Owner will pay each invoice within thirty (30) days of receipt. A service charge of one and one half percent (1.5%) per month (18% per annum) will accrue on any invoice that remains unpaid for more than thirty (30) days. Charges for labor performed after the first year of this Agreement shall be adjusted to reflect changes in Quinn's standard labor charges as in effect from time to time. At each twelve (12) month interval after the date on this document a 3% to 5% increase may be effective. If Quinn personnel arrive at the job site to perform the Maintenance Services, and are prevented from doing so through no fault of Quinn, Owner will be charged for the serviceman's time and mileage in each such instance.

This Maintenance Agreement includes travel and mileage charges to and from the job site during normal business hours. Weekend and Off-Hours requests will incur additional Labor Charges according to Exhibit "B"

Standards of Performance. Quinn shall perform the Maintenance Services in accordance with the standard of care customarily employed in the heavy equipment maintenance industry. Quinn will cooperate with Owner in scheduling performance of the Maintenance Services and Quinn will perform the Maintenance Services in a manner to minimize interference with the Owner's normal business operations to the extent reasonably possible.

Limited Duty and Liability. It is expressly agreed that the responsibility and liability of Quinn is strictly limited to performance of the Maintenance Services on the Equipment. Quinn has no responsibility or liability for failure to discover actual or potential problems in the condition or operation of the Equipment. Quinn makes no representations, warranties, or guaranties concerning the Equipment or the operation of the Equipment. Quinn shall have no liability for any consequential damages or lost profits suffered or incurred by Owner. It is expressly agreed that the total liability of Quinn to Owner whether such liability is based upon breach of contract, tort, or any other theory, shall be limited to an amount equal to the total fee payable by Owner to Quinn during the twelve (12) month period prior to such claim. It is further understood by Owner that Quinn would not enter into this Agreement or perform the Maintenance Services without obtaining the benefit of the above-described limitation on Quinn's liability to Owner.

General Provisions. This Agreement sets forth the entire agreement of the parties hereto concerning the subject matter of this Agreement. This Agreement may only be modified or amended by an agreement in writing executed by each of the parties hereto.

IN WITNESS WHEREOF, the undersigned have executed this Agreement on the date first written above.

QUINN COMPANY, a California corporation dba QUINN POWER SYSTEMS

BY:

Lee Dao

TITLE:

CSA Technical Quoter

Date:

10/21/2009

Owner: Monterey Penninsula Water District

BY:

PO #:

Date:





CSA PM LEVEL DESCRIPTIONS

CSA & SUPPORT SERVICES (800) 789-9774

(562-463-7150 Fax EXHIBIT "A"

Customer # : 440820E Agreement #: 3313AB

<---COVERED

PM Level 1 Multi Point Inspection

- Comprehensive detailed inspection of units is performed.
- Check/Adjust all fluid levels and pressures for correct operation.
- Check and inspect air cleaner restriction gauge and air filter element.
- Check primary source fuel tank for water with water finding paste.
- Check Day tank, Fuel tank, Fuel line fittings for leaks.
- Check Cooling System hoses, caps, clamps for brittleness, leaks, cracks, and weakness.
- Check ir voltages, charging rates, fluids, and specific gravities / ICV's.
- Engine cranking Batteries will be tested under start up load for voltage drop.
- Block Heater elements and inlet/outlet t-stats are checked for proper output and operation.
- Engine Fan Drive and Belts are inspected and adjusted for proper tension and condition
- Check Turbo Charger rotation / end play if so equipped.
- Check generator brushes for proper tension/setting as equipped.
- Check and document Control Panel instruments for proper operation and values
- Grease bearings, fan shafts, linkages, and equipment fittings as required.
- Hot oil sample taken and submitted for analysis.
- Test safety alarms and contacts.
- Run unit under load for up to 30 minutes when authorized by site.
- Submit report to customer.

PM Level 2 Annual Service-Major w/ Multi Point Inspection <=-COVERED

- All items from PM Level 1 are performed, PLUS
- Change crankcase oil, oil filter(s), air filter(s), fuel filter(s), water separator(s) and coolant filter(s) as equipped.
- Draw system coolant sample for analysis.

Submit report to customer.

PM Level 3 Cooling System Service

- Drain, contain and dispose of waste coolant.
- Flush cooling system with fresh water.
- Replace all coolant hoses and clamps (upgrade block heater hoses to steel braided as recommended).
- Replaced the radiator pressure cap(s)
- Replaced the engine thermostat(s) and associated gasket(s).
- Replaced the engine fan belt(s) and alternator drive belt(s).
- Refill system with proper amount of glycol antifreeze and conditioners.
- Rod and clean oil cooler or heat exchanger as equipped (if required).
- Test run unit to operating temperature, under load when authorized by site personnel.
- Return unit back to original mode of operation.
- Submit report to customer.

PM Level 4 Minor Inspection

- Perform general walk around inspection of unit.
- Fluid levels are spot checked for correct operating range.
- Inspect air filter element.
- Fuel tank/engine fuel line fittings are inspected for leaks and tighten as required.
- Coolant hoses inspected for brittleness, leaks, cracks, and weakness.
- Engine cranking batteries will be tested under start up load for voltage drop.
- Jacket water heater element and inlet/outlet t-stats are checked for proper operation.
- Engine drive belts inspected for proper tension and condition.
- Control panel instruments checked for proper operation.
- Unit is run for 10 minutes, under no load.
- Return unit back to original mode of operation.
- Submit report to customer.

PM Hourly Service per Unit Run Hours

PM Service level is based upon unit run hours as opposed calendar schedule and is typically reserved for operation and maintenance agreements.

PM PG Point Guard Monitoring

- Point Guard monitors various inputs and outputs of unit operation and functionality.
- Identifies and alerts authorized personnel of potential problems by fault notification via text or e-mail by cellular, satellite, or land-line applications

PMLB Load Bank Testing

Connect resistive or inductive load bank as applicable to generator.

- Run Test with requested load for 2, 4, or 8 hours interval
- Record readings and recommendations.
- Disconnect load bank from unit.
- Return unit back to original mode of operation.
- Submit report to customer.
- M Megohmmeter Generator Electrical Winding Test
- This test should be performed as part of periodic maintenance in order to detect the deterioration of the winding insulation.
- Perform megohmmeter test on generator winding and measure winding insulation resistance.
- Submit report to customer.

PMATS Automatic Transfer Switch Service

- De-energize the transfer switch, when possible.
- Clean unit of dust and dirt accumulations.
- Clean open-type relays of dust/grease or oil.
- Visually inspect unit for signs of arching, burning, hot spots, charring, or other damages
- Inspect for loose, broken or badly worn parts.
- Check terminal lugs and trip units for tightness / signs of overheating.
- Check main current carrying contacts for arching, pitting, and discoloration.
- Clean main contacts if needed, check and re-tighten if needed.
- Check manual switches for free movement and contact continuity
- Check and adjust relay finger contacts if needed.
- Lubricate all components for proper operation as needed.
- Check plug connections, if equipped.
- Check door closure, locking bars and handle mechanism for proper operation.
- Check exercise timer if equipped.
- Perform transfer test of ATS under load when authorized by site personnel.
- <---COVERED * Check all components/timers for proper operation and sequencing.
 - Check main power connections for heat build-up with infra-red gun or provide PM Infra-Red scan.
 - Timers reset to customer specifications and placed in automatic mode.
 - Return unit back to original mode of operation.
 - Submit report to customer.

PM Battery

Battery Replacement

- Engine cranking batteries are removed and replaced.
- Engine cranking batteries will be tested under start up load for voltage drop.
- ir disposal is provided.
- Test run unit without load.
- Return unit back to original mode of operation.
- Submit report to customer.

Infra-Red Thermography Inspection PM IR

- Problems can develop when electrical components generate excessive heat due to deterioration, loose connections, or overloads. An Infra-Red inspection is recommended to be performed on all of the following areas: generator output connections, cables, bus, and generator breakers, while system is energized. Inspection consist of:
- Set-up of Thermo graphic Imaging Infra-Red camera.
- Conduct infre-red scanning inspection.
- High resolution photographs will accompany recommendations for corrective action or repair, and will assist overall as a critical part of any complete predictive or conditional based maintenance program.
- Submit report to customer after technical review has been completed.

PM SWG Switchgear Service

Services include manufacturer recommended equipment service & inspection on single standby loads and multi-unit paralleling systems. Submit report to customer.

PM UPS UPS Service

- Services include manufacturer recommended equipment service & inspection for ir and rotary type systems
- Performance will be based upon the specific manufacturer scopes of work and whether or not the equipment is energized or de-energized.
- All services are performed only as unit is equipped and as our technician is
- Submit report to customer.

10/22/2009 9:34:22 AM





CSA LABOR RATES & CONTACTS INFO

CSA & SUPPORT SERVICES (800) 789-9774

(562-463-7150 Fax EXHIBIT "B" Customer # : 440820E Agreement # : 3313AB

EMERGENCY NUMBERS AND LABOR CHARGES

SALINAS BRANCH 1300 Abbott Street, Salinas, CA 93901

Quinn Power Systems will provide "On Call" emergency service 24 hours per day, 7 days a week with a response of 4 hours or less.

After hours, Saturdays, Sundays and holidays, call (831) 758-8461

ADDITIONAL CSA LABOR RATES ARE AS FOLLOWS:

For regular or emergency service, please call the following numbers:

Standard rate: (7:30am to 4:00pm Monday through Friday excluding Holidays)	\$106.00 \$106.00	per hour – Shop per hour – Field
<u>Overtime rate</u> : (after 4:00pm and Saturdays/holidays)	\$159.00 \$159.00	per hour – Shop per hour – Field
<u>Premium time</u> : (over 12 hours per day and Sunday)	\$212.00 \$212.00	per hour – Shop per hour – Field

Travel (truck charges) \$2.50 per mile plus Travel Time

All call outs requested OFF normal business hours; Monday through Friday, Saturdays, Sundays, and Holidays will be required to pay an hourly minimum of four (4) hours according to the prevailing billable rates within Exhibit "B". The above discounted labor rates will remain in effect until annual addendum review or upon termination of this agreement as covered in paragraph 2 under the general agreement terms.

EFFECTIVE JUNE 05, 2008

		sine sine.	. 80 m		a co. soa W als man	444 DE 100 DE 100 DE 100	Son Box and son &	1 5 cm &
CHININI OAT			SA Equipm		ent Inspection Chec			* 8 8 3 5 4 1
QUIN	LL		A Customer		20 10 10 10 10 10 10 10 10 10 10 10 10 10			•
	J	(80	0) 769-	3114		562) 463		•
Eity of Indus	try 🔳 Bakersfield		⊠ €ìx		Salinas	🖾 Santa Ma		(
3500 Shepherd St.	2200 Pagasus R		inState 801 De		1300 Abbott 8	t 1656 N. Carlott Santa Maria 93	in Dr. 48101 W	. Slama Hwy
Oty of Industry 908 (882) 463-6051	33333 (84) 393-5800 (861)	ජීම්වදි සැක්ෂිට් ශීප්පාප්පාස්ථා	4.0	1,93030 186-2171	Saimas 93901 (891)768-8461			
3277	100000000000000000000000000000000000000	1			Achiver			
5777	**************************************	arni actures,	!		Driven Na	outachuse		
Date Agreements		del Number			A COLUMN TO THE REAL PROPERTY OF THE PARTY O	del Number		
Service Level		rial Number			The second secon	ial Number		
(Smit #	Service	eter Units	35	ectric Ho	×375	Driven	Elosiki .	
(C) CHECK	(S) SERVICE (A	ADJUST	(R) REPLAC	E (X) I	VEEDS ATTEN	TION (N/A)	NOT APPLI	CABLE
Service Check			Ge ge	nerators				100000000000000000000000000000000000000
20000000000000000000000000000000000000		000000000000000000000000000000000000000	22222 george	000000000000000000000000000000000000000	annonnonnonnonnonnonnon	Sectionized by C	88888888888888888888888888888888888888	.00000000000000000000000000000000000000
Obesia Suthouses	knon and Acress			of KAA.	KVA	JAN JAN	rk'r	\$0
Check Oil Level Check Coolant Le	, viud			ood Actu		Not	H SEUDIA DEO	2
Check Operation	50	ļ	VAC		880	1§2		Flæ
	Expansion Tank Cap			dr Exciter	/ Regulator Co	nnechons		
Coolant Protection	Constitution .	solant ph			s / Slip Rings			
oil ksi		120 Terries	Links	e George et	or Bearing as N	GCCC SOLA		
Alterator Charge	Radas Radas R	DE Arigis	Che	de ATS for	rtleanmess/S			
Engine Speed	KDM Genera	tor Freq	Gen	Breaker)	Found	Control Panel I	ţ	
Check / Correct !	Manar Gilleaks		Gera	Breakers	left.	Control Panel	3. 525°C	
	Same Codeant Leaks		Sa	fety Syst	terns		******************	
Check / Correct!	Winnerual Leaks		,		entalina kaj cata: mmmmmmmmm	Daver C	833500000000000000000000000000000000000	20000049999999999
Participation and Control of the Con	ger Rotation / End Pl	яķ		mis minim		Firms &	especial .	
Chade Governor			Similar	arger (1)	itrut and Batt	ery Condition	\$5655665566566666666666666666666666666	200000000000000000000000000000000000000
Exbricabe Govern	- 34 - 3A				-			<i>Communication</i>
Check Hoses (Britie, Cracks, Weak) Check / Fighten Hose Clamps		ļ	1	ery Type	. r		a A Gronts	
inear/ ngnen	and the second s	ļ		ery Date		Quantity e Coat/Tighten I	no boore	ter:
Libricate Fee Dr			1	ery #1	coc.	e coat righten	The state of the s	
the state of the s	tells as Required			Gry #1	Airea	13	+	
	with Water Finding Fa	sbe		ery #2	v.C.C.	S		12
Check Daytank (and the second s			48 y 48 Z	cgrr4.	5		13
Inspect Air Filter	Carrier of the Control of the Contro		1		at Start-Up	,	MDC	VOC
Is Thoma Evidence	a of Webstacking?		- Ant	i-Convosio	n Battery Post	4pplicators	100000000000000000000000000000000000000	000000000000000000000000000000000000000
SOS Analysis:		ANT 🖾 F	CEL M	iterials L	Ised	disconsistant description of the second		
Spark Ignited	Engines	AREA REAL PROPERTY OF THE PERSON OF THE PERS	35,030,00	amamanang Brand		Oil Type	yiQ liD	GE2
Check Point Gap	000000000000000000000000000000000000000	100000000000000000000000000000000000000	200000000	Filter l		Fuel Fillow		
	be Carburator Linkage			illier 1	1	Uil Filter 2		
Check / Adjust A			Air	Filter			300000000000000000000000000000000000000	000000000000000000000000000000000000000
Check / Bap Spa		2	000000	300/100000000000000000	Service Recui	(22)		
	s for Brittlersess		Second	W. Let 5000	manamanaman Recoverended?	99899999999999	500000000000000000000000000000000000000	***************************************
Check Huy Wire				5 4 55	king Reconsise			
Check Distributor Cap / Robor		· · · · · · · · · · · · · · · · · · ·		PNO Cooling Sys. Soc Recommended?				
Check / Adjust Tirring				prof. Eathery Replacement Recommended?				
Recommendations:		8-1.5	Fixed Polishing Suc Recommended?					
	Weight Re-							
								,
hard and the second	4 22 1			· v	chierosias I		red ins	
Castorner Signs	x the			2.65	equinci ser			ļ
			WWW.QUIN	NPOWER	.com	\$	13-11.8	Ouplicate
	******************************		******	******	***************************************	***************************************	aliiiiiiiiiiiakiii	





PREVENTIVE MAINTENANCE SCHEDULE

CSA & SUPPORT SERVICES (800) 789-9774

Customer #: 440820E Agreement #: 3313AB

Customer:

Monterey Penninsula Water District

Address:

P.O.Box 85

MONTEREY

CA 93942

Date: 10/21/2009

Phone No. 831-649-4866

Fax No. 831-644-9560

Corey Hamilton

Perform Preventive Maintenance Service and Inspections on the Following.

Engine Description		PM LEVEL 1: PM LEVEL 2: LQADBANK: PM LEVEL 3	TOTAL
Calerpillar 3306ATAAC, SN 09NR04306	LABOR:	\$431.00 \$643.00 \$1,050.00 \$1,517.00	\$4,732.00
#1: Monterey Ca	EST. PARTS:	\$35.00 \$336.00 \$720.00	