

ATTACHMENT 1

TABLE 2: NON-RESIDENTIAL WATER USE FACTORS

<u>Group I – Low to Moderate Use</u>				<u>0.00007 AF/SF</u>	
Auto Uses	Retail	Warehouse	Dental/Medical/Veterinary Clinics	Fast Photo	
Church	Nail Salon	Family Grocery	Office	School	Bank Gym Supermarket
<i>Dry Cleaner (No on-site laundry)</i>		<i>Convenience Store</i>			

Group II—High Use 0.0002 AF/SF
Users in this category prepare and sell food/beverages that are primarily provided to customers on disposable tableware. Food with high moisture content and liquid food may be served on reusable tableware. Pizza must be served on reusable platters or on disposable plates. Glassware may be used to serve beverages.

Bakery	Pizza	Coffee House	Convenience Store <i>Ice Cream Shop</i>
<i>Catering</i>	Dry Cleaner <i>Deli</i>	<i>Bistro</i>	Sandwich Shop

Group III—Miscellaneous Uses – Each Category is Calculated Separately

Assisted Living (more than 6 beds) ²	0.085 per bed
Beauty Shop/Dog Grooming	0.0567 AF/station
Child Care	0.0072 AF/child
Dormitory ¹	0.040 AF/room
Gas Station	0.0913 AF/pump
Laundromat	0.200 AF/machine
Meeting Hall	0.00053 AF/sf
Motel/Hotel/Bed and Breakfast:	0.100 AF/room
w/Large Bathtub (add to room factor)	0.030 AF/tub
Irrigated areas not immediately adjacent (i.e. within 10 feet of any bldg):	ETWU
Plant Nursery	0.00009 AF/sf total land
Public Toilets	0.058 AF/toilet
Public Urinals	0.036 AF/toilet
Zero Water Consumption Urinal(s)	No Value
Restaurant (General/Bar):	0.020 AF/seat
Restaurant (24-Hour & Fast Food):	0.038 AF/seat
Self-Storage	0.0008 AF/storage unit
Skilled Nursing	0.120 AF/bed
Spa	0.050 AF/spa
Swimming Pool	0.020 AF/100 sf surface area
Theater	0.0012 AF/seat

Group IV- Modified Non-Residential Uses – Users listed in this category have reduced water Capacity from the types of uses

For all new Connections -- Refer to Rule 24-B-2, Exterior Non-Residential Water Demand Calculations.

Note: Any Non-Residential water use which cannot be characterized by one of the use categories set forth in Table 2 shall be designated as “other” and assigned a factor which has a positive correlation to the anticipated Water Use Capacity for that Site. Unenclosed structures are exempt from the Non-Residential Permit requirements and have no Water Credit value.

¹ Dormitory water use at educational facilities is a Residential use although the factor is shown on Table 2.

² Assisted living Dwelling Units shall be permitted as Residential uses per Table 1, Residential Fixture Unit Count Values