## TABLE 2: NON-RESIDENTIAL WATER USE FACTORS

## Group I

Auto Uses Retail Warehouse Dental Clinic Office Bank Supermarket
Church Nail Salon Family Grocery Medical Clinic Wine Tasting Room Fast Photo Convenience Store

Dry Cleaner (No On-Site Laundry)

Veterinary Clinic School Gym

# Group II

Users in this category prepare and sell food/beverages that are primarily provided to customers on disposable tableware. Food with high moisture content and liquid food may be served on reusable tableware. Pizza must be served on reusable platters or on disposable plates. Glassware may be used to serve beverages.

Bakery Pizza Coffee House Ice Cream Shop Catering Deli Bistro Sandwich Shop

#### **Group III**

Assisted Living (more than 6 beds)<sup>1</sup>

Beauty Shop/Dog Grooming

Child/Dependent Adult Day Care

0.085 AF/Bed

0.0567 AF/Station

0.0072 AF/Child-Person

Dormitory<sup>2</sup> 0.040 AF/Room

Gas Station 0.0913 AF/<del>Pump-Fuel Dispenser</del>

Laundromat0.2 AF/MachineMeeting Hall/Banquet Room0.00053 AF/SF

Motel/Hotel/Bed & Breakfast:

w/Large Bathtub (Add to room factor)

0.1 AF/Room
0.03 AF/Tub

Irrigated Areas beyond ten feet of any building ETWU

Plant Nursery 0.00009 AF/SF<del>-Total</del> Land *Area* 

Public Toilets

0.058 AF/Toilet

Public Urinals

0.036 AF/Urinal

Zero Water Consumption Urinal(s) No Value

Restaurant (including Bar/Brewpub Seats) 0.02 AF/Interior Restaurant Seat

Exterior Restaurant Seats above the ''Standard Exterior Seat Allowance''<sup>3</sup> 0.01 AF/Exterior Restaurant Seat

Exterior Restaurant Seats within the "Standard Exterior Seat Allowance" No Value

Restaurant (24-Hour and Fast Food) 0.038 AF/Interior Restaurant Seat

Self-Storage Unit

Skilled Nursing/*Alzheimer's Care* 0.12 AF/Bed

Spa 0.05 AF/Spa

Swimming Pool 0.02 AF/100 SF of Surface Area

Theater 0.0012 AF/Seat

# **Group IV - MODIFIED NON-RESIDENTIAL USES**

Users listed in this category have reduced water Capacity from the types of uses listed in Groups I-III and have received a Water Use Credit for modifications. The General Manager shall maintain a list of specific properties in this Group that have received a Water Use Credit pursuant to Rule 25.5 for permanent reduction in use. Please inquire for specific property information.

All New Connections: Refer to Rule 24-B, Exterior Non-Residential Water Demand Calculations

Notes: Any Non-Residential water use which cannot be characterized by one of the use categories set forth in Table 2 shall be designated as "other" and assigned a factor which has a positive correlation to the anticipated Water use Capacity for that Site.

Unenclosed structures are exempt from the Non-Residential Permit requirements and have no Water Credit value.

<sup>&</sup>lt;sup>1</sup> Assisted living Dwelling Units shall be permitted as Residential uses per Table 1, Residential Fixture Unit Count Values.

<sup>&</sup>lt;sup>2</sup> Dormitory water use at educational facilities is a Residential use, although the factor is shown on Table 2.

<sup>&</sup>lt;sup>3</sup> See Rule 24-B-1 and Rule 25.5 for information about the "Standard Exterior Seat Allowance"