
EXHIBIT 19-B




Notes:

1. Application 32263A assumed no minimum bypass and maximum 6 cfs diversion rate (blue bars). Average Yeild 2,620 AFY

2. NMFS requested that 2 cfs be bypassed from APR 1 to OCT 31 in years when the SDRF is not operating (Letter of 2/16/2016).

3. Local agencies propose to comply with a 2 cfs bypass, if lagoon conditions warrant the bypass (see May 2016 Memo). Yield reductions shown reflect a year when the conditions for the 2 cfs bypass are met for the full time period of interest (April 1 through and including October 31). Average Yield 1771 AF (32% reduction)

EXHIBIT 19-B




Notes:

1. Proposed diversion (A32263B) included seasonal bypass of 0.7 cfs (JUN-NOV) and 2.0 cfs (DEC-MAY). Average annual yield 1,521 AFY.

2. EIR mitigation measure and MCWRA Protest Response (March 2016) offered to cease diverting when flows reached 40 cfs and to not commence diverting for 72 hours after flow recedes below 40 cfs

3. NMFS requested and local agencies agree to cease diverting from Reclamation Ditch when flows exceed 30 cfs, and to not recommence diverting again until flows recede below 20 cfs. Average annual yield 1,030 AFY (32% reduction)

EXHIBIT 19-B



Notes:

1. Blue bars show average monthly flow in Reclamation Ditch at the San Jon Road gage. Average flow 6,928 AFY.

2. Proposed diversion (A32263B) included seasonal bypass of 0.7 cfs (JUN-NOV) and 2.0 cfs (DEC-MAY). Average annual yield 1,521 AFY.

3. EIR mitigation measure and MCWRA Protest Response (March 2016) offered to cease diverting when flows reached 40 cfs and to not commence diverting for 72 hours after flow recedes below 40 cfs

4. NMFS requested and local agencies agree to cease diverting from Reclamation Ditch when flows exceed 30 cfs, and to not recommence diverting again until flows recede below 20 cfs. Average annual yield 1,030 AFY (32% reduction).