

	Residential New	Non-Res New	Change of Ownership and Water Permit Conditions	Change of Use	Mandatory Requirements	Messaging Requirements
Toilets	HET (1.3 gpf)	HET (1.3 gpf)	HET (1.3 gpf)	HET (1.3 gpf) for older than 10 year old ULFs	HET (1.3 gpf) upon replacement from 2010-2013 then mandatory retrofit (exception for recently installed toilets)	
Urinals	0.125 max	0.125 max. Zero water urinals encouraged	0.125 max. Zero water urinals encouraged	0.125 max. Zero water urinals encouraged	By 2013, High Efficiency Urinals	
Showerheads	2.0 gpm	2.0 gpm w/scald protection	2.0 gpm	2.0 gpm	N/A	
Multiple showerheads	3-minute timer	3-minute timer	N/A	N/A	N/A	
Lavatory faucets	1.5 @ 60 psi	0.5 @ 60 psi for all applications other than hotel/motel guest rooms and private hospital rooms.	1.5 @ 60 psi (Residential) and 0.5 @ 60 psi for all applications other than hotel/motel guest rooms and private hospital rooms.	0.5 @ 60 psi for all applications other than hotel/motel guest rooms and private hospital rooms.	0.5 @ 60 psi for all applications other than hotel/motel guest rooms and private hospital rooms.	
Automatic faucet or sensor shut-offs		0.25 gpm max	N/A	0.25 gpm max	0.25 gpm max	
High Efficiency Washers	Water Factor 5.0 max	Water Factor 5.0 max			Required by 2013 w/ max water factor of 5.0	

	Residential New	Non-Res New	Change of Ownership and Water Permit Conditions	Change of Use	Mandatory Requirements	Messaging Requirements
High Efficiency Dishwashers	5.8 gpc max	Meet or exceed CEE specifications				
IAHWS	Required	Required	Modifications that involve hot water			
Insulation of Hot Water Pipes	Required	Required	Modifications that involve hot water			
Sodium Water Softeners	Discouraged	Discouraged				
Model Landscape Ord.	Required	Required				
WBIC	Required on Sites w/ irrigation system for areas >2000 sf	Required on Sites w/ irrigation system for areas >2000 sf				
Rain Sensors	Required for all non-WBIC automatic irrigation systems	Required for all non-WBIC automatic irrigation systems	Required for all non-WBIC automatic irrigation systems		Encouraged for all automatic irrigation systems	
Soil Moisture Sensors	Encouraged	Encouraged				
Drip Irrigation for Non-Turf	Required for non-turf irrigation	Required for non-turf irrigation				
Water Efficient Spray Heads for Turf Irrigation	Required for turf irrigation	Required for turf irrigation				

	Residential New	Non-Res New	Change of Ownership and Water Permit Conditions	Change of Use	Mandatory Requirements	Messaging Requirements
Overhead Spray Ban for Non-Turf Areas	Required	Required				
Rainwater Collection	Encouraged	Encouraged				
Alternative Irrigation Source Signage						Encouraged
Best Management Practices		Required	Implement in Non- Residential to extent possible	Implement in Non- Residential to extent possible		
Pre-Rinse Spray Valves		1.6 gpm max	1.6 gpm max	1.6 gpm max	1.6 gpm max by July 1, 2010	
Single-Pass Water Use Systems when non- water technology is available		Prohibited			Air-cooled ice machines required by 2013	
Water Cooled Refrigeration		Prohibited when non- water technology is available				
Cooling Tower Conductivity Controllers		Required				
Boilerless Steamers in Place of Boiler-based Steamers		Required				

	Residential New	Non-Res New	Change of Ownership and Water Permit Conditions	Change of Use	Mandatory Requirements	Messaging Requirements
Car Wash 50% Recycled					Currently required	
Mobile Water Systems Metering					Required	
Towel/Linen Reuse					Required	
Drinking Water on Request Only					Required	Currently Required
Conservation Messages						Currently Required