

submitted by  
Staff - item 5

**TABLE 2: NON-RESIDENTIAL WATER USE FACTORS**

<u>Group I - Low to Moderate Use</u>				<u>0.00007 AF/SF</u>		
Auto Uses	Retail	Warehouse	Dental/Medical/Veterinary Clinics	Fast Photo		
Church	Nail Salon	Family Grocery	Office	School	Bank	Gym Supermarket

<u>Group II – High Use</u>			<u>0.0002 AF/SE</u>	
Bakery	Pizza	Coffee House	Convenience Store	
Dry Cleaner	Deli		Sandwich Shop	

Group III- Miscellaneous Uses - Each Category is Calculated Separately

Assisted Living (more than 6 beds) <sup>2</sup>	0.085 per bed
Beauty Shop/Dog Grooming	0.0567 AF/station
Child Care	0.0072 AF/child
Dormitory <sup>1</sup>	0.040 AF/room
Gas Station	0.0913 AF/pump
Laundromat	0.200 AF/machine
Meeting Hall	0.00053 AF/sf
Motel/Hotel/Bed and Breakfast:	0.100 AF/room
w/Large Bathtub (add to room factor)	0.030 AF/tub
Irrigated areas not immediately adjacent (i.e. within 10 feet of any building): ETWU	
Plant Nursery	0.00009 AF/sf total land
Public Toilets	0.058 AF/toilet
Public Urinals	0.036 AF/urinal
Zero Water Consumption Urinal(s)	No value
Restaurant (General/Bar):	0.020 AF/seat
Restaurant (24-Hour & Fast Food):	0.038 AF/seat
Self-Storage	0.0008 AF/storage unit
Skilled Nursing	0.120 AF/bed
Spa	0.050 AF/spa
Swimming Pool	0.020 AF/100 sf surface area
Theater	0.0012 AF/seat

Group IV- Modified Non-Residential Uses – Users listed in this category have reduced water Capacity from the types of uses listed in Groups I-III and have received a Water Use Credit for modifications. The General Manager shall maintain a list of specific properties in this Group that have received a Water Use Credit pursuant to Rule 25.5 for permanent reduction in use.

For all new Connections -- Refer to Rule 24-B-2, Exterior Non-Residential Water Demand Calculations.

Note: Any Non-Residential water use which cannot be characterized by one of the use categories set forth in Table 2 shall be designated as “other” and assigned a factor which has a positive correlation to the anticipated Water Use Capacity for that Site.

Note: Unenclosed structures are exempt from the Non-Residential Permit requirements and have no Water Credit value.

<sup>1</sup> Dormitory water use at educational facilities is a Residential use although the factor is shown on Table 2.

<sup>2</sup> Assisted living Dwelling Units shall be permitted as Residential uses per Table 1, Residential Fixture Unit Count Values  
Table amended by Ordinance No. 125 (9/29/2006); Resolution 2008-01 (1/24/2008); Resolution 2010-15 (12/13/2010);  
Resolution 2013-16 (9/16/13)