



LIGHT FIXTURE SCHEDULE

TYPE	DESCRIPTION	LAMPS	MANUFACTURER
A	2' x 4' Surface Mtd Flourecent Fixture Electronic Ballast, 120V Acrylic Prismatic Lens Pattern #12	(4) F32 T8	Wellmade 128 Series
A1	Same as Type A, except 2 tube	(2) F32 T8	Wellmade 128 Series
B	Surface Mtd. fixture. 120V Metal Halide	(1) 50W, MH	Ruud E4
C	Incandescent Porcelain Base, Owner Provided, Contractor Installed	(1) 40W	
D	Surface Mtd. Flour. Fixture. Owner Provided, Contractor Installed	(2) F32 T8	

SLEEPY HOLLOW STEELHEAD REARING FACILITY

SCALE: 1/4" = 1 ft	APPROVED BY	DRAWN BY DH Dettman
DATE: 11/1/94		

MONTEREY PENINSULA WATER MANAGEMENT DISTRICT

LIGHTING AND OUTLET CIRCUITS

DRAWING NUMBER
10 / E3

Notes:

1. (11) Aqua-monitor System, water quality monitoring/control instrument. Six station monitoring of oxygen and temperature with digital relay control of six remote devices.
2. (12) (13) 24-hour timers, eight stations, independent control of eight 24V relays.
- (T1) (T2) 120V/24V Transformers, 24V power for (12) & (13)