

- BRASS METER COUPLING, SHORT, MALE (3)
- 6 STREET ELBOW
- WATTS CHECK VALVE ASSEMBLY,
   BY CITY (WATTS 007 DUAL CHECK)
- (9) B-36 METER BOX WITH READING

## NOTES:

- 1. METER SIZE VARIES FROM 3/4" TO 1-1/2" MAXIMUM (VERIFY SIZE WITH CITY), STANDARD FIRE SPRINKLER SYSTEM REQUIRED FOR FIRE SERVICES LARGER THAN 1-1/2".
- 2. SEPARATE PRIVATE SERVICE LINES ARE REQUIRED FOR DOMESTIC WATER AND FIRE PROTECTION NEEDS. THESE SERVICE LINES MUST BE INSTALLED BY THE CUSTOMER PER UNIFORM PLUMBING CODE REQUIREMENTS.
- 3. ALL PRIVATE INSTALLATION ACTIVITY SHALL COMPLY WITH THE CITY ORDINANCE No. 13.04 AS AMENDED REGARDING "WATER SERVICES AND CHARGES".
- 4. CUSTOMER SHALL INSTALL SUITABLE CONTROL VALVES ON EACH PRIVATE SERVICE LINE ON THE RISER TO EACH BUILDING OR A MAXIMUM OF 50' FROM THE METER. THE VALVES SHALL CONTROL THE ENTIRE WATER SUPPLY FROM THE SURFACE.
- 5. THE MAXIMUM PERMITTED NUMBER OF DWELLING UNITS CONNECTED TO A COMBINATION RESIDENTIAL FIRE SPRINKLER SHALL NOT EXCEED ONE (1) UNIT.
  PROJECTS WHICH EXCEED THIS LIMITATION MUST INCLUDE A SEPARATE, DEDICATED
  FIRE SERVICE LINE FOR RESIDENTIAL FIRE PROTECTION.

DEPARTMENT OF PUBLIC WORKS CITY OF GONZALES COMBINATION DOMESTIC & FIRE SERVICE DETAIL TITLE: STANDARD PLAN DESIGNED BY APPROVED: Exp. 3-31-97 DATE: WAG/MKL DRAWN BY: MKL CITY ENGINEER: CHECKED BY: SAM ZULLO RE #14692 SJZ