



RESOLUTION NO. 2016-04

**A RESOLUTION OF THE BOARD OF DIRECTORS OF THE
MONTEREY PENINSULA WATER MANAGEMENT DISTRICT
AMENDING RULE 24 – TABLE 1 RESIDENTIAL FIXTURE UNIT COUNT VALUES**

WHEREAS District Rule 24-A.1.b *Residential Calculation of Water Use Capacity*, allows changes to Table 1: Residential Fixture Unit Count Values through Resolution of the Board of Directors, and;

WHEREAS in compliance with recently adopted Ordinance No. 167 (Rule 142, Water Efficiency Standards Amendment), amended the Water Efficiency Standard for Urinals as adopted on April 8, 2015, by the California Energy Commission. As of January 1, 2016, newly installed Urinals shall flush with no more than 0.125 gallon per flush (Pint Urinals).

WHEREAS amendment of Table 1: Residential Fixture Unit County Values to reflect the new fixture unit value is in compliance with the direction of Ordinance No. 167.

NOW, THEREFORE, the Board of Directors of the Monterey Peninsula Water Management District resolves that Table 1: Residential Fixture Unit Count Values shall be amended to reflect the amendment to the Water Efficiency Standard for Urinals as amended in Ordinance No. 167, as shown in ***bold/italics*** and ~~striketrough~~ on Attachment 1.

On motion of Director Pendergrass, and second by Director Potter, the foregoing resolution is duly adopted this 17th day of February, 2016, by the following vote:


AYES: Directors Pendergrass, Potter, Brower, Byrne, Clarke and Evans

NAYS: None

ABSENT: Director Lewis

I, David J. Stoldt, Secretary to the Board of Directors of the Monterey Peninsula Water Management District, hereby certify that the foregoing is a resolution duly adopted on the 17th day of February, 2016.

Witness my hand and seal of the Board of Directors this 4th day of March, 2016.


David J. Stoldt, Secretary to the Board of Directors

Attachment 1 to MPWMD Resolution 2016-04

TABLE 1: RESIDENTIAL FIXTURE UNIT COUNT VALUES

	Water Fixture Description	Fixture Unit Value
1	Washbasin (lavatory sink), each	1
2	Two Washbasins in the Master Bathroom	1
3	Toilet, Ultra Low Flush (1.6 gallons per flush)	1.8
4	Toilet, High Efficiency (HET) (1.3 gallons maximum)	1.3
5	Toilet, Ultra High Efficiency (UHET) (0.8 gallon maximum)	0.8
6	Urinal, High Efficiency (0.5 gallon per flush) Pint (0.125 gallon maximum)	0.5 0.1
7	Urinal, Zero Water Consumption	0
8	Bathtub, (may be Large with Showerhead above) & Separate Shower in the Master Bathroom	3
9	Bathtub, Large (may have Showerhead above)	3
10	Bathtub, Standard (may have Showerhead above) or Shower Stall (one Showerhead)	2
11	Shower, each additional fixture (including additional Showerheads, Body Spray Nozzles, etc.)	2
12	Shower System, Rain Bars, or Custom Shower (varies according to specifications)	2
13	Kitchen Sink (including optional adjacent Dishwasher) ¹	2
14	Kitchen Sink with adjacent High Efficiency Dishwasher (5.8 gallons maximum per cycle)	1.5
15	Dishwasher, each additional (including optional adjacent sink)	2
16	Dishwasher, High Efficiency, each additional (including optional adjacent sink) [5.8 gallons maximum per cycle]	1.5
17	Laundry Sink/Utility Sink (debit/Capacity Fee applies to only one Laundry/Utility Sink per Residential)	2
18	Clothes Washer	2
19	Clothes Washer, High Efficiency (HEW) (Water Factor of 5.0 or less)	1
20	Bidet	2
21	Bar Sink	1
22	Entertainment Sink	1
23	Vegetable Sink	1
24	Swimming Pool (each 100 square-feet of pool surface area)	1
25	For all new Connections -- Refer to Rule 24-A-5, Exterior Residential Water Demand Calculations.	

¹ When a Kitchen Sink exists without the benefit of a Dishwasher, a Dishwasher may be added without a Water Permit.

Table Amended by Resolution 2009-11 (8/17/2009); Ordinance No. 140 (11/16/2009); Resolution 2009-13 (12/14/2009); Resolution 2010-15 (12/13/2010); Ordinance No. 151 (11/19/2012); Ordinance No. 156 (11/18/2013); Resolution 2016-04 (2/17/2016)