



**FINAL  
RESOLUTION 2021-14**

**A RESOLUTION OF THE BOARD OF DIRECTORS OF THE  
MONTEREY PENINSULA WATER MANAGEMENT DISTRICT AMENDING  
RULE 24, TABLE 1: RESIDENTIAL FIXTURE UNIT COUNT VALUES**

**WHEREAS**, it has consistently been the practice of the Water Management District to include the Capacity for use of a High Efficiency Clothes Washer for each Residential Dwelling Unit that has access to a Common Laundry Room; and

**WHEREAS**, the addition of the factor for a Common Laundry Room to Table 1 will codify the long-standing practice used when calculating Capacity for Water Permits in Multi-Family Dwellings and Common Interest Developments; and

**WHEREAS**, amendment of Table 1: Residential Fixture Unit County Values to reflect the fixture unit value (Water Use Capacity) ensures consistency in the application of the District's Residential Water Permit process.

**NOW, THEREFORE, BE IT RESOLVED**, that the Board of Directors of the Monterey Peninsula Water Management District adopts amendments to Table 1: Residential Fixture Unit Count Values to include the Common Laundry Room factor, as shown in *bold/italics* and ~~strikethrough~~ on **Attachment 1**.

**PASSED AND ADOPTED** on this 15<sup>th</sup> day of November 2021 on a motion by Director Paull with a second by Director Riley by the following vote, to wit:

AYES: Director Edwards, Paull, Malek, Roberson, Adams, Riley and Anderson

NAYS: None

ABSENT: None

I, David J. Stoldt, Secretary to the Board of Directors of the Monterey Peninsula Water Management District, hereby certify the foregoing resolution was duly adopted on the 15th day of November 2021.

  
\_\_\_\_\_  
David J. Stoldt, Secretary to the Board

U:\staff\Resolutions\2021\Final Resolution No. 2021-14.docx

**Attachment 1 to MPWMD Resolution No. 2021-14**

**TABLE 1: RESIDENTIAL FIXTURE UNIT COUNT VALUES**

	Water Fixture Description	Fixture Unit Value
1	Washbasin (lavatory sink), each	1
2	Two Washbasins in the Master Bathroom	1
3	Toilet, Ultra Low Flush (1.6 gallons per flush)	1.8
4	Toilet, High Efficiency (HET) (1.3 gallons maximum)	1.3
5	Toilet, Ultra High Efficiency (UHET) (0.8 gallon maximum)	0.8
6	Urinal, Pint (0.125 gallon maximum)	0.1
7	Urinal, Zero Water Consumption	0
8	Bathtub, (may be Large with Showerhead above) & Separate Shower in the Master Bathroom	3
9	Bathtub, Large (may have Showerhead above)	3
10	Bathtub, Standard (may have Showerhead above) or Shower Stall (one Showerhead)	2
11	Shower, each additional fixture (including additional Showerheads, Body Spray Nozzles, etc.)	2
12	Shower System, Rain Bars, or Custom Shower (varies according to specifications)	2
13	Kitchen Sink (including optional adjacent Dishwasher)	2
14	Kitchen Sink with adjacent High Efficiency Dishwasher (5.8 gallons maximum per cycle)	1.5
15	Dishwasher, each additional (including optional adjacent sink)	2
16	Dishwasher, High Efficiency, each additional (including optional adjacent sink) [5.8 gallons maximum per cycle]	1.5
17	Laundry Sink/Utility Sink (debit/Capacity Fee applies to only one Laundry/Utility Sink per Residential)	2
18	Clothes Washer	2
19	<i>Clothes Washer, Common Laundry Room (per Dwelling Unit with access to the CLR)</i>	2
20	Clothes Washer, High Efficiency (HEW) (Water Factor of 5.0 or less)	1
21	Bidet	2
22	Bar Sink	1
23	Entertainment Sink	1
24	Vegetable Sink	1
25	Swimming Pool (each 100 square-feet of pool surface area)	1
26	For all new Connections -- Refer to Rule 24-A-5, Exterior Residential Water Demand Calculations.	

<sup>1</sup>When a Kitchen Sink exists without the benefit of a Dishwasher, a Dishwasher may be added without a Water Permit.