

RULE 59 - WELL CONSTRUCTION STANDARDS

In addition to the water Well standards of the State of California and the County of Monterey, all new Wells within the District shall be equipped with a sounding tube. Where the Well uses an electrical motor pump, that pump shall be metered separately from any other power use except booster pumps.

Rule added by Ordinance No. 3 (7/11/80); amended by Ordinance No. 4 (2/11/81); Ordinance No. 6 (5/11/81); Ordinance No. 122 (8/15/2005)