


1 SITE ELECTRICAL PLAN
SCALE: 1"= 16'-0"

- NOTES:
- VFD CABLE SHALL BE PULLED FROM THE BUILDING TO THE WELL TO PREVENT DAMAGE TO THE PVC CONDUIT IN THE BUILDING.



KIYOI ENGINEERING INC.
5266 Hollister Avenue #117
Santa Barbara, CA 93111
Phone: (805) 681-0980

REV	DATE	BY	DESCRIPTION
2	8/8/2013	RLK	ISSUE FOR BID
1	5/24/2013	RLK	ISSUE FOR CONSTRUCTION

SCALE:
HOR. 1"=XX
VER. 1"=XX

WARNING
0
IF THIS BAR DOES NOT MEASURE 1" THEN DRAWING IS NOT TO SCALE

DESIGNED RLK
DRAWN WNS
CHECKED RLK



Pueblo Water Resources
4478 Market St., Suite 705
Ventura, CA 93003
(805) 644-0470

UNAUTHORIZED CHANGES & USES CAUTION:
The engineer preparing these plans will not be responsible for, or liable for, unauthorized changes to or uses of these plans. All changes to the plans must be in writing and must be approved by the preparer of these plans.

MPWMD Phase II ASR Project
Installation of Owner-Purchased Electrical Equipment
SITE ELECTRICAL PLAN

PROJECT NO.
E-1