

Date: October 16, 2017

To: Board of Directors

From: Stephanie Locke, Water Demand Manager

Subject: Public Hearing Item 6, First Reading of Ordinance No. 178

Proposed Edit to Definition of High Efficiency Toilet for Ordinance No. 178 Public Hearing:

HIGH EFFICIENCY TOILET (HET) – “High Efficiency Toilet” or “HET” shall mean a toilet *designed with* ~~that has~~ *a maximum* an effective flush volume of ~~20 percent below a 1.6 gallons-per-flush maximum or less, equating to a maximum of~~ 1.28 gallons per flush *and that is labeled by the U.S. Environmental Protection Agency’s WaterSense program*. (Note: The HET category includes dual-flush fixtures, which have been determined to meet the volume requirement by defining the effective flush volume as the average volume achieved with one full flush and two reduced flushes.)